



NOTES:

1. SAWCUTS SHALL BE PLACED IN THE SIDEWALK AT THE BOTTOM OF THE CURB TRANSITION.
2. DEPRESSED CURB AND GUTTER AT DRIVEWAY ENTRANCES SHALL HAVE AN ADDITIONAL 50mm BENCH TO SUPPORT ADJACENT CONCRETE RAMPS, REFER TO OPSD 600.040.
3. DRIVEWAY TO BE MINIMUM 1.2m FROM ANY STREET FURNITURE.
4. REFER TO CW-221 FOR COLOURED IMPRESSED CONCRETE COLOUR AND DETAILS.

ALL DIMENSIONS ARE IN MILLIMETERS UNLESS OTHERWISE SHOWN.

STANDARD DRAWINGS

CURB-FACE SIDEWALK DRIVEWAY RAMP DETAIL

REV 1 MAY 2023



CW-212