



**NOTES:**

1. PROVIDE 25mm DIA. SERVICES FOR LOTS.
2. TRACER WIRE TO BE INSTALLED PER THE CITY OF WATERLOO TRACER WIRE SPECIFICATION.
3. ALL MECHANICAL JOINTS TO BE MECHANICALLY RESTRAINED.
4. CORROSION PROTECTION TO BE AFFIXED AS PER THE DGSSMS.

ALL DIMENSIONS ARE IN MILLIMETERS UNLESS OTHERWISE SHOWN.

**STANDARD DRAWING**

REV 1      MAY 2023

**CUL-DE-SAC WATER SERVICING DETAIL**



**CW-311**