



NOTES:

1. BOTH YARD HYDRANT AND MASTER 2126 LOCK ARE AVAILABLE FOR PURCHASE FROM CITY OF WATERLOO STOCK ROOM (STOCK ROOM ID# 72425 AND ID# 72839). PHONE 519-747-8752 TO ORDER.
2. INSTALLATION OF THE WATER SERVICE REQUIRES A BUILDING PERMIT AND ENGINEERING ACCEPTANCE
3. ENSURE LINE ON WHICH HYDRANT IS TO BE INSTALLED HAS BEEN THOROUGHLY FLUSHED TO WASH OUT FOREIGN PARTICLES. DRAIN HOLE IN CLEAR STONE SELF DRAINAGE AREA.
4. ENSURE THE HYDRANT IS INSTALLED AND TESTED WITH PROVISION FOR OPTIMAL DRAINAGE BELOW THE FROST LINE.
5. INSTALL AS PER MANUFACTURER'S RECOMMENDATIONS AS APPROVED BY CITY OF WATERLOO.
6. YARD HYDRANT IS TO BE LOCATED MINIMUM 3000 FROM RINK SITE AND MAXIMUM 7500 FROM RINK SITE.
7. ENSURE THE HYDRANT SPOUT IS FACING THE IDENTIFIED RINK SITE
8. FOR OUTDOOR COMMUNITY PARK HYDRO PANEL DETAILS CONTACT THE CITY PROJECT MANAGER FOR THE LATEST STANDARDS.

ALL DIMENSIONS ARE IN MILLIMETERS UNLESS OTHERWISE SHOWN.

STANDARD DRAWING

REV 1

MAY 2023

STANDARD YARD HYDRANT

THE CITY OF
Waterloo

CW-312