



ELEVATION VIEW



PLAN VIEW

NOTES:

1. METER TO BE INSTALLED BY BUILDER/PLUMBER WITHIN 1 m FROM WHERE THE WATER SERVICE ENTERS THE DWELLING.
2. BRING 25 mm COPPER SERVICE INTO ALL RESIDENTIAL DWELLINGS AND REDUCE TO 19 mm COPPER AT THE FIRST STOP.
3. ALL METERS MUST BE ACCESSIBLE FOR READING AND MAINTENANCE FUNCTIONS. ANY OBSTRUCTIONS WILL BE BASIS FOR TERMINATION OF THE WATER SUPPLY.
4. ALL METERS ARE MARKED WITH A WATER FLOW DIRECTIONAL ARROW. PLEASE MAKE SURE ARROW CORRESPONDS WITH WATER FLOW.
5. REMOVE COUPLINGS & GASKETS FROM METER BEFORE SOLDERING, HEAT WILL DAMAGE THE INTERIOR OF THE METER.
6. ALL METER SETTINGS MUST HAVE A SHUT OFF VALVE BEFORE AND AFTER THE METER.
7. ALL METERS MUST BE INSTALLED USING THE SUPPLIED METER COUPLINGS AND GASKETS. NO OTHER MATERIAL WILL BE ACCEPTED.
8. NO CONNECTIONS SUCH AS BUT NOT LIMITED TO, CHECK VALVES, PRESSURE REDUCING VALVES, GAUGES PERMITTED UPSTREAM OF WATER METER.
9. FOLLOW WIRING DIRECTIONS THAT ARE PROVIDED WITH METER.
10. FOR ASSISTANCE CALL THE METER SHOP @ 519-886-2310 EXT 30250.

ALL DIMENSIONS ARE IN MILLIMETERS UNLESS OTHERWISE SHOWN.

STANDARD DRAWING

REV 1

MAY 2023

STANDARD 15mm METER ASSEMBLY DETAIL



CW-331