

August 14, 2020

GSP Group
72 Victoria Street South, Suite 201
Kitchener, ON N2G 2A9

Attention: Ms. Kristen Barisdale MCIP RPP
Planner

Dear Ms. Barisdale,

**Re: Preliminary Environmental Noise Impact Assessment
556 and 576 Conservation Drive
City of Waterloo**

This letter is being provided as a follow-up to the Preliminary Environmental Noise Impact Assessment submitted for the above-noted project and dated May 11, 2018. The revised Draft Plan has replaced all individual lots at the south end of the site along Conservation Drive – the traffic noise generator – with multi-residential blocks that will be developed through the Site Plan process.

The noise modelling included in the 2018 Assessment showed that noise attenuation measures and noise warning clauses for indoor and outdoor noise levels are not required at distances of 40m and greater from the centerline of Conservation Drive. Block 27 is now the nearest block of street townhomes and is approximately 100m from the centerline of Conservation Drive; therefore, noise modeling is no longer necessary in support of the Draft Plan submission. Blocks 29 and 30 will require individual noise assessments in support of Site Plan Approval.

Yours very truly,

MERITECH ENGINEERING



Stefan Van Hartingsveldt, C.E.T.
Project Lead



Chris H. Togeretz, P.Eng.
Manager, Design Services

SVH/
Enclosures (0)

cc